



Pete K. Rahn, Director

**ADDENDUM 001
REQUEST FOR BID (RFB)
D610-146-RW DEMOLITION SALT DOME**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original quote. The due date for receipt of this quote **does NOT change** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Terri Mount Sr. General Services Specialist
Bidder Signature	Department of Transportation <i>Terri Mount</i>
Signature of person authorized to sign	Authorizing Signature
Date Signed:	Date Signed: 5/10/10

Are the storage bins to be included also with the demolition of the Salt Dome, or are we to only include the Salt Dome?

MODOT RESPONSE: The metal storage bins and the small storage sheds shown in the aerial photo have already been removed by MoDOT. Only the salt dome is included in the bid.

What size does the concrete ring need to be downsized to in order to leave on-site for fill material?

MODOT RESPONSE: Exhibit B of the bid package is MoDOT's Standard Specifications for Demolition and Removal work. Standard Specification 202.3.2.1 requires broken concrete that will be used as fill material to be broken up into pieces not exceeding 4 square feet.

THIS ADDENDUM MUST BE SIGNED AND SUBMITTED WITH RESPONSE.